

# Utah Department of Environmental Quality

## Division of Drinking Water

### Public Water System Inventory Report

Run Date:  
08/04/2011 12:54 pm

**PWS ID:** UTAH25092      **Name:** UTAH STATE HOSPITAL  
**Legal Contact:** UTAH STATE HOSPITAL      **Rating:** Approved  
VAL DEAN BONNETT      **Rating Date:** 11/28/1984  
**Address:** 1300 E CENTER ST      **Activity Status:** Active  
PROVO, UT 84603  
**Phone Number:** 801-344-4743  
**City Served (Area):**  
**County:** UTAH COUNTY  
**System Type:** Community      **Last Inv Update:** 12/27/2010      **Avg Daily Prod:**  
**Activity Status Cd:** Active      **Last Snty Srv Dt:** 09/28/2010      **Total Dsgn Cap:**  
**Population:** 800      **Surveyor:** BOYD STRINGHAM      **Total Emerg Cap:**  
**Oper Period:** 1/1 to 12/31

Gal/Day Gal/Min

### Contacts

Contact Type	Name	Title	Phone Numbers		Email Address
			Office	Emergency	
AC	BONNETT, VAL DEAN		801-344-4743	801-377-9115	vbonnett@utah.gov

### Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Residential	Unmetered	0	25
			25 Total Svc Connections

### Storage

**Total Storage:** 430,000 GAL      **Number of Units:** 2      **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST001	110 K (OLD) TANK	Ground	110,000 GAL	Concrete		A	NO
ST002	320 K (NEW) TANK	Ground	320,000 GAL	Concrete		A	NO

### Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

### Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	SLATE CANYON SPRING	Active	SP				Yes	GW	Permanent	1/1 to 12/31	
WS002	UTAH HOSPITAL WELL	Active	WL	8	450 GPM	450 GPM	Yes	GW	Permanent	1/1 to 12/31	
WS003	UTAH25006 PROVO CITY	Active	CC				Yes	GW	Permanent	1/1 to 12/31	
WS004	OAK SPRINGS	Inactive	SP				Yes	GW	Other		

\*Reports measured flow for wells, approved design capacity for all other sources.